



DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-6102CQ0573

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Aalberts integrated piping systems Ltd. St. Catherines Avenue, GB- Doncaster DN4 8DF
Distributor <i>Vertreiber</i>	Aalberts integrated piping systems B.V. Oude Amersfoortseweg 99, NL-1212 AA Hilversum
Product Category <i>Produktart</i>	Stop valves for drinking water: Ball valve (6102)
Product description <i>Produktbezeichnung</i>	ball valve with reduced bore and push connectors
Model <i>Modell</i>	TX300
Test reports <i>Prüfberichte</i>	Laboratory control test: V284/24-2 from 17.10.2024 (MPM) Type testing: 120004453-1 from 18.02.2015 (MPM)
Test basis <i>Prüfgrundlagen</i>	DVGW W 570-1 (01.03.2013) DIN EN 13828 (01.12.2003)

Date of Expiry / File No. 18.02.2027 / 24-0947-WNV
Ablaufdatum / Aktenzeichen

70028-04-A-DE

11.12.2025 Gre A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-00

DVGW CERT GmbH
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 9188-888
info@dvgw-cert.com
www.dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
TX300	Noise emission class: I Pressure rating: PN 10 Nominal diameter: DN 15	
TX300	Noise emission class: I Pressure rating: PN 10 Nominal diameter: DN 20	

Hints of Utilization / Remarks***Verwendungshinweise / Bemerkungen***

type of connection: push connectors "Tectite" according DVGW-system-certification DW-8511BL0274; 15 mm and 22 mm

The hygienic safety of all materials that come into contact with drinking water has been proven.

